



STATE LICENSE NO. C57 432880

P.O. Box 845 • Atascadero, California 93423 • (805) 466-1271

Name	<u>Peter Boysen</u>	Date	<u>8/24/2005</u>
Address	<u>P.O. Box 568 Linden, CA 95236</u>	Phone	<u>209-481-3752</u>
Job Location	<u>1990 Sycamore Canyon Dr.</u>	Fax	
Well size	<u>8"</u> Depth <u>140'</u>	Duration of test	<u>24 +1hr recovery</u>
Tested by	<u>Dustin</u> Rate of flow (gpm) <u>150</u>	Static level	<u>18.5</u>

Well Test Report

<u>Date</u>	<u>Time</u>	<u>Water level</u>	<u>G.P.M.</u>
<u>8/24/2005</u>	<u>2:00pm</u>	<u>18.5</u>	<u>150</u>
	2:05	67.9	150
	2:10	72.7	150
	2:15	77.4	150
	2:20	80	150
	2:30	80.7	150
	2:45	84.2	150
	3:00	84.6	150
	3:30	85.3	150
	4:00	85.9	150
	5:00	86.2	150
	6:00	86.9	150
	7:00	87.4	150
	8:00	88.2	150
	9:00	88.8	150
	10:00	89.3	150
	11:00	89.5	150
	12:00	89.9	150
	1:00	90.2	150
	2:00	90.4	150
	3:00	90.4	150
	4:00	90.6	150
	5:00	90.8	150
	6:00	90.9	150
	7:00	91.2	150
	8:00	91.5	150
	9:00	91.6	150
	10:00	92	150
	11:00	92.2	150
<u>8/25/2005</u>	<u>12:00</u>	<u>92.3</u>	<u>150</u>
	1:00	92.4	150
	2:00	92.5	150

Recovery Test

<u>8/25/2005</u>	<u>Time</u>	<u>Water level</u>
	2:00	0
	2:05	25.5
	2:10	23.3
	2:15	23
	2:20	22.8
	2:30	22.6
	2:45	22.3
	3:00	22

Thank you,



Ned M. Thompson